

Site : Teesdale Development Corporation - Thornaby Site Phase I

Typical Analysis			
Material	Before Treatment	After Treatment	Consent Limit
pH	7-8	7-8	5-10
Phenol	2	<1	---
CN	1.5	<0.1	---
NH3	100	<10	<10
Pb	200	30ppb	<100
Cd	150	20ppb	<100
Suspended Solids	1000 +	<30	<150
Benzene	< 10		
Toulene	< 10		
Xylene	< 10	<1ppm	<2ppm
Ethyl Benzene	< 10	Total	Total
Mesitylene	< 10		
Styrene	< 10		
Napthalene	63	<5	
Acenaphthalene	16	<1	
Fluorene	7	<1	
Phenanthrene	85	<1	<25ppm
Anthracene	1.5	<1	Total
Fluoranthene	4	<1	
Pyrene	2	<1	